18-0170

Cook

JUN 04 2010

2010 MAY 11 PM 1:58

ATC ASSOCIATES INC.

11117 Mockingbird Drive
Omaha, Nebraska 68137
www.atcassociates.com
Phone: 402.697.9747
Fax: 402.697.9170

April 9, 2010

Tennessee Dept. of Environment & Conservation
Div. of Air Pollution Control
9th Floor, L&C Annex
401 Church Street
Nashville, TN 37243-1531

RE: U.S. Cellular® - Emergency Generator Air Permit Applications

Dear Sir or Madam:

ATC Associates, Inc. was retained by U.S. Cellular® to complete air permit applications for their emergency generators within the State of Tennessee pursuant to APC Rule Ch. 1200. Upon review of U.S. Cellular's databases and through confirmation with their Network Field Engineers, ATC determined that U.S. Cellular currently has fifteen (15) generators within the State of Tennessee that are required to obtain air permits.

Attached are the Air Permit Application Forms (Form APC20, Form APC21&24 and APC22) for the fifteen (15) generators along with a check in the amount of $1,500.00 ($100.00/facility) for the permit fees. Also attached is a list of the fifteen (15) facilities with generators.

If you should have any questions, please do not hesitate to call me at (515) 981-3216.

Sincerely,
ATC ASSOCIATES INC.

Mike Freese

Mike Freese, REM
Sr. Project Manager

Attachments

cc: Doug Zabrin – U.S. Cellular®
Brad Summers – U.S. Cellular®
Dale Mattson – U.S. Cellular®
Jerry Williams – U.S. Cellular®
Mark Clark – U.S. Cellular®
Tony Chandler – U.S. Cellular®

Permit Required Facilities

Site #	Site Name	Site Address	Site City	Site State	Site Zip	Site County	Site Contact	Contact Phone	Gen. Mfr.	Gen. Model	Gen. Size (KW)	Generator Fuel Type
411316	411316 RATTLESNAKE DT	347 Tower Road	Gatlinburg	TN	37738	Sevier	Brad Summers	865.705.7600	Cummins	DGGD	35	DSL - Diesel
860327	860327 HARTSVILLE	136 Morrison Street	Hartsville	TN	37074	Trousdale	Dale Mattson	Not Listed	Kohler	50REOZJC	37	DSL - Diesel
860333	860333 RED BOILING SPRINGS	8101 Heady Ridge Rd.	Red Boiling Springs	TN	37150	Macon	Dale Mattson	Not Listed	Kohler	50REOZJC	37	DSL - Diesel
860338	860338 WESTSIDE	461 Green Grove Rd.	Lafayette	TN	37083	Macon	Dale Mattson	Not Listed	Kohler	50REOZJC	37	DSL - Diesel
860319	860319 PIONEER	8638 Sticking Creek Rd.	Pioneer	TN	37847	Campbell	Jerry Williams	865.679.4446	Kohler	50REOZJC	37	DSL - Diesel
860348	860348 PEAVINE	653 Eroh Rd.	Crossville	TN	38571	Cumberland	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860359	860359 ROBBINS	East Robbins Rd.	Robbins	TN	37852	Scott	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860362	860362 PINEY	252 Old Harriman Hwy.	Harriman	TN	37748	Roane	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860367	860367 CORDELL	8787 James Baker Highway	Huntsville	TN	37756	Scott	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860368	860368 MOFFIT	4496 Straight Fork Road	Pioneer	TN	37847	Scott	Mike Clark	931.979.0041	Kohler	30REOZJC	27	DSL - Diesel
860381	860381 STEPHENS	180 Tree Top Lane	Coalfield	TN	37719	Morgan	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
411346	411346 DOUGLAS DAM	1443 Holbert Road	Dandridge	TN	37725	Sevier	Tony Chandler	865.679.0010	Kohler	50REOZJC	37	DSL - Diesel
860354	860354 CRAB ORCHARD	384 Godsey Road	Crab Orchard	TN	37723	Cumberland	Mike Clark	931.979.0041	Kohler	30REOZJC	27	DSL - Diesel
860358	860358 GLEN MARY	593 Huckelby Road	Robbins	TN	37852	Scott	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860345	860345 TANSI	490Vandiver Rd.	Crossville	TN	38571	Cumberland	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel

0860	05/06/2010	R 0000199217	1500009260

INVOICE NUMBER	DATE	AMOUNT	DISCOUNT	NET AMOUNT
050510 AIR PERMIT FEES	05/05/2010	$1,500.00		$1,500.00

2010 MAY 11 PM 1:58

Tennessee RSA No. 3 LP
8410 W Bryn Mawr Ave
Suite 700
Chicago, IL 60631-3415

REMOVE DOCUMENT ALONG THIS PERFORATION

Tennessee RSA No. 3 LP
8410 W Bryn Mawr Ave
Suite 700
Chicago, IL 60631-3415

U.S. Cellular

1500009260
BANK OF AMERICA
2-3
710 IL

DATE
May 06, 2010

0860 0000199217

PAY ONLY $1,500.00

VOID IF NOT CASHED WITHIN 180 DAYS OF ISSUE

One thousand five hundred and 00/100 Dollars

PAY TO THE ORDER OF
State of Tennessee
Dept of Environment - Conservation
401 Church Street
NASHVILLE TN 37243

⑈1500009260⑈ ⑆071000039⑆ 5800963430⑈

Remove this stub before cashing. Fold, crease, and tear along perforation.

1500009260

0860 0000199217

Tennessee RSA No. 3 LP
8410 W Bryn Mawr Ave
Suite 700
Chicago, IL 60631-3415

U.S. Cellular

$1,500.00 each of this fee applies to 15 different permits

State of Tennessee
Dept of Environment - Conservation
401 Church Street
NASHVILLE TN 37243

Call **1-800-PICK-UPS®** (1-800-742-5877) or visit **ups.com®**.

- For UPS Next Day Air services, there is no weight limit for envelopes containing letters, business correspondence, urgent documents, and electronic media. When a UPS Next Day Air service is selected, UPS Express Envelopes containing items other than those listed above are subject to the corresponding rates for the applicable weight.
- Express Envelopes are not recommended for shipments of electronic media containing sensitive personal information.
- For UPS Worldwide Express, the UPS Express Envelope may be used only for documents of no commercial value. There is no limit on the weight or number of pages you can enclose.
- Do not use UPS 2nd Day Air services to send letters weighing over 13 ounces in this envelope. For UPS 2nd Day Air services, UPS Express Envelopes weighing one pound or more are subject to the corresponding rates for the applicable weight.

Reusable Express Envelope

Legal Size

Decision Green℠

Decision Green is UPS's environmental platform, reflecting our pursuit of sustainable business practices worldwide. For example, this envelope is made from 100% recycled material and is both reusable and recyclable.

100% Recycled fiber
80% Post-Consumer

PATRICE GOODWIN
773-399-8999
US CELLULAR CORPORATE
8410 W BRYN MAWR AVENUE
CHICAGO IL 60631

2 LBS 1 OF 1

SHIP TO:
TENNESSEE DEPT OF ENVIROMENTAL
DIV OF AIR POLLUTION CONTROL
9TH FLOOR L&C ANNEX
401 CHURCH ST.
NASHVILLE TN 37219-2310

TN 371 9-02

UPS 2ND DAY AIR 2

TRACKING #: 1Z 61X 045 02 9859 4810

BILLING: P/P

Cost Center: 175105

CS 12.0.26. WXPIE60 03.0A 04/2010

UPS CampusShip: Lat

Page 1 of 2

velope is for use
following services:

velope for:

ted®

I: SOU
KROB – 8010
P: WHITE S: BR2
1Z61X045029859 4810
DIV OF AIR POLLUTION CONTROL
401 CHURCH ST
NASHVILLE TN 37219-2218

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF AIR POLLUTION CONTROL

9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone:(615) 532-0554
FAX: (615) 532-0614

NOT TO BE USED FOR TITLE V APPLICATIONS

2010 MAY 11 PM 1:59

PERMIT APPLICATION

APC 20

PLEASE TYPE OR PRINT AND SUBMIT IN DUPLICATE FOR EACH EMISSION SOURCE. ATTACH APPROPRIATE SOURCE DESCRIPTION FORMS.

1. ORGANIZATION'S LEGAL NAME US Cellular		/ / / FOR	APC COMPANY--POINT NO. 18-0170
2. MAILING ADDRESS (ST/RD/P.O. BOX) 8410 W. Bryn Mawr Avenue, Suite 900		/ / / APC	APC LOG/PERMIT NO. 63691
CITY Chicago	STATE Illinois	ZIP CODE 60631	PHONE WITH AREA CODE 773-399-7925
3. PRINCIPAL TECHNICAL CONTACT John Glatz/US Cellular Mike Freese/ATC Associates			PHONE WITH AREA CODE 773-399-6899 515-981-3216
4. SITE ADDRESS (ST/RD/HWY) 384 Godsey Road (Site known as 860354 Crab Orchard)			COUNTY NAME Cumberland
CITY OR DISTANCE TO NEAREST TOWN Crab Orchard		ZIP CODE 37723	PHONE WITH AREA CODE 931-979-0041 Mike Clark – Network Field Eng.
5. EMISSION SOURCE NO. (NUMBER WHICH UNIQUELY IDENTIFIES THIS SOURCE) ES-1		PERMIT RENEWAL YES ( ) NO (X)	

6. BRIEF DESCRIPTION OF EMISSION SOURCE

Backup Emergency Generator (Kohler Model 30REOZJC)

7. TYPE OF PERMIT REQUESTED

CONSTRUCTION (X)	STARTING DATE Installed 7/09	COMPLETION DATE	LAST PERMIT NUMBER	EMISSION SOURCE REFERENCE NUMBER
OPERATING (X)	DATE CONSTRUCTION STARTED Installed 7/09	DATE COMPLETED	LAST PERMIT NUMBER	EMISSION SOURCE REFERENCE NUMBER
LOCATION TRANSFER ( )	TRANSFER DATE		LAST PERMIT NUMBER	EMISSION SOURCE REFERENCE NUMBER

ADDRESS OF LAST LOCATION

8. DESCRIBE CHANGES THAT HAVE BEEN MADE TO THIS EQUIPMENT OR OPERATION SINCE THE LAST CONSTRUCTION OR OPERATING PERMIT APPLICATION.

9. SIGNATURE (APPLICATION MUST BE SIGNED BEFORE IT WILL BE PROCESSED) John Glatz		**DATE** 4/30/10
10. SIGNER'S NAME (TYPE OR PRINT) John Glatz	**TITLE** Director Real Estate Services	**PHONE WITH AREA CODE** 773-399-6899

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF AIR POLLUTION CONTROL

NOT TO BE USED FOR TITLE V APPLICATIONS

9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone:(615) 532-0554
FAX: (615) 532-0614

2010 MAY 11 PM 1:59

PROCESS OR FUEL BURNING SOURCE DESCRIPTION

APC21(& 24)

PLEASE TYPE OR PRINT, SUBMIT IN DUPLICATE AND ATTACH TO THE PERMIT APPLICATION.

1. **ORGANIZATION NAME**		/ / / FOR	APC COMPANY-POINT NO.
US Cellular			
2. **EMISSION SOURCE NO.** (AS ON PERMIT APPLICATION)	SIC CODE	/ / / APC	APC PERMIT/LOG NO.
ES-1	4812		

3. DESCRIPTION OF PROCESS OR FUEL BURNING UNIT

Backup Emergency Generator (Kohler Model 30REOZJC)

4. **NORMAL OPERATION**: → Emergency generator is exercised on a periodic basis	HOURS/DAY	DAYS/WEEK	WEEKS/YEAR	DAYS/YEAR
5. **PERCENT ANNUAL THROUGHPUT:** →	DEC.-FEB.	MARCH-MAY	JUNE-AUG.	SEPT.-NOV.
	25%	25%	25%	25%

6. **TYPE OF PERMIT APPLICATION**	(CHECK BELOW ONE ONLY)
PROCESS SOURCE: APPLY FOR A SEPARATE PERMIT FOR EACH SOURCE. (CHECK AT RIGHT, AND COMPLETE LINES 7, 8, 13, AND 14).	( )
PROCESS SOURCE WITH IN-PROCESS FUEL: PRODUCTS OF COMBUSTION CONTACT MATERIALS HEATED. APPLY FOR A SEPARATE PERMIT FOR EACH SOURCE. (CHECK AT RIGHT, AND COMPLETE LINES 7, 8, AND 10 THROUGH 14)	( )
NON-PROCESS FUEL BURNING SOURCE: PRODUCTS OF COMBUSTION DO NOT CONTACT MATERIALS HEATED. COMPLETE THIS FORM FOR EACH BOILER OR FUEL BURNER AND COMPLETE AN EMISSION POINT DESCRIPTION FORM (APC 22) FOR EACH STACK. (CHECK AT RIGHT, AND COMPLETE LINES 9 TO 14)	(X)

7. TYPE OF OPERATION: CONTINUOUS,	BATCH	NORMAL BATCH TIME	NORMAL BATCHES/DAY
( )	( )		

8. **PROCESS MATERIAL INPUTS AND IN-PROCESS SOLID FUELS**	DIAGRAM* REFERENCE	INPUT RATES (POUNDS/HOUR) DESIGN	ACTUAL	/ /	(FOR APC USE ONLY) SCC CODE
A.				/ /	
B.				/ /	
C.				/ /	
D.				/ /	
E.				/ /	
F.				/ /	
G.				/ /	
TOTALS				/ /	

* A SIMPLE PROCESS FLOW DIAGRAM MUST BE ATTACHED.

(OVER)

APC 21 (& 24)

9. BOILER OR BURNER DATA: (COMPLETE LINES 9 TO 14 USING A SEPARATE FORM FOR EACH BOILER)

BOILER NUMBER	STACK NUMBER**	TYPE OF FIRING***	RATED BOILER HORSEPOWER	RATED INPUT CAPACITY (10^6 BTU/HR)	OTHER BOILER RATING (SPECIFY CAPACITY AND UNITS)
ES-1	EP-1				27 kilowatt

BOILER SERIAL NO.	DATE CONSTRUCTED	DATE OF LAST MODIFICATION (EXPLAIN IN COMMENTS BELOW).
2258155	July 2009	NA

** BOILERS WITH A COMMON STACK WILL HAVE THE SAME STACK NUMBER.

*** CYCLONE, SPREADER (WITH OR WITHOUT REINJECTION), PULVERIZED (WET OR DRY BOTTOM, WITH OR WITHOUT REINJECTION), OTHER STOKER (SPECIFY TYPE), HAND FIRED, AUTOMATIC, OR OTHER TYPE (DESCRIBE BELOW IN COMMENTS).

10. FUEL DATA: (COMPLETE FOR A PROCESS SOURCE WITH IN-PROCESS FUEL OR A NON-PROCESS FUEL BURNING SOURCE)

PRIMARY FUEL TYPE (SPECIFY): Diesel Fuel

STANDBY FUEL TYPE(S) (SPECIFY)

FUELS USED	ANNUAL USAGE	HOURLY USAGE		%	%	BTU VALUE		(FOR APC ONLY)
		DESIGN	AVERAGE	SULFUR	ASH	OF FUEL		SCC CODE
NATURAL GAS:	10^6 CUFT	CUFT	CUFT	/ / / / / / / /	/ / / / /			
#2 FUEL OIL: Diesel Fuel	10^3 GAL <100 gal./year	GAL:4.3 gal./hr. @ full standby	GAL: 3.6 gal./hr. @ full prime	<0.5%	/ / / /	140,000/gal.		20200102
#5 FUEL OIL:	10^3 GAL	GAL	GAL		/ / / /			
#6 FUEL OIL:	10^3 GAL	GAL	GAL		/ / / /			
COAL:	TONS	LBS	LBS					
WOOD:	TONS	LBS	LBS	/ / / / / / / /	/ / / /			
LIQUID PROPANE:	10^3 GAL	GAL	GAL	/ / / / / / / /	/ / / /			
OTHER (.SPECIFY TYPE & UNITS.):								

11. IF WOOD IS USED AS A FUEL, SPECIFY TYPES AND ESTIMATE PERCENT BY WEIGHT OF BARK

12. IF WOOD IS USED WITH OTHER FUELS, SPECIFY PERCENT BY WEIGHT OF WOOD CHARGED TO THE BURNER.

13. COMMENTS: Process Flow Diagram below.



14. SIGNATURE

DATE 4/30/2010

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF AIR POLLUTION CONTROL

NOT TO BE USED FOR TITLE V APPLICATIONS

9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone:(615) 532-0554
FAX: (615) 532-0614

2010 MAY 11 PM 1:59

EMISSION POINT DESCRIPTION

APC 22

PLEASE TYPE OR PRINT AND SUBMIT IN DUPLICATE FOR EACH STACK OR EMISSION POINT.
ATTACH TO THE PERMIT APPLICATION.

1. ORGANIZATION NAME US Cellular			/ / / FOR	APC COMPANY POINT NO.
2. EMISSION SOURCE NO. (FROM APPLICATION) ES-1		FLOW DIAGRAM POINT NUMBER EP-1	/ / / APC	APC SEQUENCE NO.
3. LOCATION: →	LATITUDE 35.895009	LONGITUDE -84.859176	UTM VERTICAL	UTM HORIZONTAL
4. BRIEF EMISSION POINT DESCRIPTION (ATTACH A SKETCH IF APPROPRIATE): Exhaust for emergency generator				DISTANCE TO NEAREST PROPERTY LINE (FT) Remote cell location >50 ft.

COMPLETE LINES 5 AND 6 IF DIFFERENT FROM THAT ON THE PROCESS OR FUEL BURNING SOURCE DESCRIPTION (APC 21)

5. NORMAL OPERATION: →	HOURS/DAY Emergency generator is exercised on a periodic	DAYS/WEEK	WEEK/YEAR		DAYS/YEAR
6. PERCENT ANNUAL THROUGHPUT: →	DEC.-FEB. 25%	MARCH-MAY 25%	JUNE-AUG. 25%		SEPT.-NOV. 25%
7. STACK OR EMISSION POINT DATA: →	HEIGHT ABOVE GRADE (FT) ~5'	DIAMETER (FT) 0.2	TEMPERATURE (°F) 1026	% OF TIME OVER 125°F	DIRECTION OF EXIT (UP, DOWN OR HORIZONTAL) Vertical
DATA AT EXIT CONDITIONS: →	FLOW (ACTUAL FT^3/MIN.) 283	VELOCITY (FT/SEC)	MOISTURE ($GRAINS/FT^3$)		MOISTURE (PERCENT)
DATA AT STANDARD CONDITIONS: →	FLOW (DRY STD. FT^3/MIN) 283	VELOCITY (FT/SEC)	MOISTURE ($GRAINS/FT^3$)		MOISTURE (PERCENT)

8. AIR CONTAMINANTS	ACTUAL EMISSIONS						
	EMISSIONS (LBS/HR)		CONCENTRATION	AVG. (TONS/YR)	EMISSIONS* EST. METHOD	CONTROL DEVICES*	CONTROL EFFICIENCY%
	AVERAGE	MAXIMUM					
PARTICULATES	0.11	0.12	**	0.03	3		
SULFUR DIOXIDE	0.10	0.11	***	0.03	3		
CARBON MONOXIDE	0.33	0.36	PPM	0.09	3		
ORGANIC COMPOUNDS	0.12	0.14	PPM	0.03	3		
NITROGEN OXIDES	1.51	1.69	PPM	0.42	3		
FLUORIDES				<0.01			
OTHER(SPECIFY)	Above emissions based on full prime	Above emissions based on full standby		Emissions above based on 500hrs/yr and full standby.	Above based on SCC 20200102		

(OVER)

9. CHECK TYPES OF MONITORING AND RECORDING INSTRUMENTS THAT ARE ATTACHED:
OPACITY MONITOR ( ), SO2 MONITOR ( ), NOX MONITOR ( ), OTHER (SPECIFY IN COMMENTS) (X)

10. COMMENTS

Hour meter

11. SIGNATURE	**DATE**
John Steel	4/30/2010

* REFER TO THE BACK OF THE PERMIT APPLICATION FORM FOR ESTIMATION METHOD AND CONTROL DEVICE CODES.

** EXIT GAS PARTICULATE CONCENTRATION UNITS: PROCESS — GRAINS/DRY STANDARD FT3 (70°F); WOOD FIRED BOILERS — GRAINS/DRY STANDARD FT3 (70°F); ALL OTHER BOILERS — LBS/MILLION BTU HEAT INPUT.

*** EXIT GAS SULFUR DIOXIDE CONCENTRATIONS UNITS: PROCESS — PPM BY VOLUME, DRY BASES; BOILERS — LBS/MILLION BTU HEAT INPUT.

Model: 30REOZJC

KOHLER POWER SYSTEMS

208-600 V Diesel

ISO 9001 KOHLER POWER SYSTEMS NATIONALLY REGISTERED

Ratings Range

		60 Hz
Standby:	**kW**	27-30
	kVA	27-38
Prime:	**kW**	24-26
	kVA	24-33



Standard Features

- Kohler Co. provides one-source responsibility for the generating system and accessories.
- The generator set and its components are prototype-tested, factory-built, and production-tested.
- The 60 Hz generator set offers a UL 2200 listing.
- The generator set accepts rated load in one step.
- The 60 Hz generator set meets NFPA 110, Level 1, when equipped with the necessary accessories and installed per NFPA standards.
- The generator set engine is certified by the Environmental Protection Agency (EPA) to conform to interim Tier 4 nonroad emissions regulations.
- A one-year limited warranty covers all systems and components. Two-, five-, and ten-year extended warranties are also available.
- Alternator features:
  - The unique Fast-Response™ II excitation system delivers excellent voltage response and short-circuit capability using a permanent magnet (PM)-excited alternator.
  - The brushless, rotating-field alternator has broadrange reconnectability.
- Other features:
  - Controllers are available for all applications. See controller features inside.
  - The low coolant level shutdown prevents overheating (standard on radiator models only).
  - Integral vibration isolation eliminates the need for under-unit vibration spring isolators.

Generator Set Ratings

				130°C Rise Standby Rating		105°C Rise Prime Rating	
Alternator	**Voltage**	**Ph**	**Hz**	**kW/kVA**	**Amps**	**kW/kVA**	**Amps**
4P5	120/208	3	60	30/38	104	25/31	87
	127/220	3	60	30/38	98	25/31	82
	120/240	3	60	30/38	90	25/31	75
	120/240	1	60	27/27	113	24/24	100
	139/240	3	60	30/38	90	25/31	75
	220/380	3	60	30/38	57	25/31	47
	277/480	3	60	30/38	45	25/31	38
	347/600	3	60	30/38	36	25/31	30
4P7	120/208	3	60	30/38	104	26/33	90
	127/220	3	60	30/38	98	26/33	85
	120/240	3	60	30/38	90	26/33	78
	120/240	1	60	28/28	117	25/25	104
	139/240	3	60	30/38	90	26/33	78
	220/380	3	60	30/38	57	26/33	49
	277/480	3	60	30/38	45	26/33	39
	347/600	3	60	30/38	36	26/33	31
4Q4	120/240	1	60	28/28	117	25/25	104

RATINGS: All three-phase units are rated at 0.8 power factor. All single-phase units are rated at 1.0 power factor. *Standby Ratings:* Standby ratings apply to installations served by a reliable utility source. The standby rating is applicable to varying loads for the duration of a power outage. There is no overload capability for this rating. Ratings are in accordance with ISO-3046/1, BS 5514, AS 2789, and DIN 6271. *Prime Power Ratings:* Prime power ratings apply to installations where utility power is unavailable or unreliable. At varying load, the number of generator set operating hours is unlimited. A 10% overload capacity is available for one hour in twelve. Ratings are in accordance with ISO-8528/1, overload power in accordance with ISO-3046/1, BS 5514, AS 2789, and DIN 6271. For limited running time and base load ratings, consult the factory. Obtain the technical information bulletin (TIB-101) on ratings guidelines for the complete ratings definitions. The generator set manufacturer reserves the right to change the design or specifications without notice and without any obligation or liability whatsoever. GENERAL GUIDELINES FOR DERATION: *Altitude:* Derate 0.5% per 100 m (328 ft.) elevation above 2100 m (6890 ft.). *Temperature:* Derate 1.0% per 10°C (18°F) temperature above 25°C (77°F).

Alternator Specifications

Specifications	Alternator
Manufacturer	Kohler
Type	4-Pole, Rotating-Field
Exciter type	Brushless, Permanent-Magnet
Leads: quantity, type	
4Q4	4, 110-120/220-240
4P5, 4P7	12, Reconnectable
Voltage regulator	Solid State, Volts/Hz
Insulation:	NEMA MG1
Material	Class H
Temperature rise	130°C, Standby
Bearing: quantity, type	1, Sealed
Coupling	Flexible Disc
Amortisseur windings	Full
Voltage regulation, no-load to full-load	
Decision-Maker 550 controller (with 0.5% drift due to temp. variation)	3-Phase Sensing, ±0.25%
Decision-Maker 3000 controller	3-Phase Sensing, ±0.5%
One-step load acceptance	100% of Rating
Unbalanced load capability	100% of Rated Standby Current
Peak motor starting kVA:	(35% dip for voltages below)
480 V 4P5 (12 lead)	140
480 V 4P7 (12 lead)	194
240 V 4Q4 (4 lead)	72

- NEMA MG1, IEEE, and ANSI standards compliance for temperature rise and motor starting.
- Sustained short-circuit current of up to 300% of the rated current for up to 10 seconds.
- Sustained short-circuit current enabling downstream circuit breakers to trip without collapsing the alternator field.
- Self-ventilated and dripproof construction.
- Vacuum-impregnated windings with fungus-resistant epoxy varnish for dependability and long life.
- Superior voltage waveform from a two-thirds pitch stator and skewed rotor.
- Fast-Response™ II brushless alternator with brushless exciter for excellent load response.

Application Data

Engine

Engine Specifications	
Manufacturer	John Deere
Engine model	4024TF281B
Engine type	4-Cycle, Turbocharged
Cylinder arrangement	4 Inline
Displacement, L (cu. in.)	2.4 (149)
Bore and stroke, mm (in.)	86 x 105 (3.39 x 4.13)
Compression ratio	20.5:1
Piston speed, m/min. (ft./min.)	375 (1230)
Main bearings: quantity, type	5, Replaceable Insert
Rated rpm	1800
Max. power at rated rpm, kWm (BHP)	36 (49)
Cylinder head material	Cast Iron
Crankshaft material	Ductile Iron
Valve material:	
Intake	Chromium-Silicon Steel
Exhaust	Stainless Steel
Governor: type, make/model	Electronic, Stanadyne/Unit Pump
Frequency regulation, no-load to full-load	Isochronous
Frequency regulation, steady state	±0.25%
Frequency	Fixed
Air cleaner type, all models	Dry

Exhaust

Exhaust System	
Exhaust manifold type	Dry
Exhaust flow at rated kW, m^3/min. (cfm)	8.0 (283)
Exhaust temperature at rated kW, dry exhaust, °C (°F)	552 (1026)
Maximum allowable back pressure, kPa (in. Hg)	7.5 (2.2)
Exhaust outlet size at engine hookup, mm (in.)	63.5 (2.5)

Engine Electrical

Engine Electrical System	
Battery charging alternator:	
Ground (negative/positive)	Negative
Volts (DC)	12
Ampere rating	70
Starter motor rated voltage (DC)	12
Battery, recommended cold cranking amps (CCA):	
Quantity, CCA rating	One, 640
Battery voltage (DC)	12

Fuel

Fuel System	
Fuel supply line, min. ID, mm (in.)	11.0 (0.44)
Fuel return line, min. ID, mm (in.)	6.0 (0.25)
Max. lift, engine-driven fuel pump, m (ft.)	3.0 (10.0)
Max. fuel flow, Lph (gph)	99 (26.1)
Fuel prime pump	Manual
Fuel filter	
Secondary	5 Microns @ 98% Efficiency
Water Separator	Yes
Recommended fuel	#2 Diesel

Lubrication

Lubricating System	
Type	Full Pressure
Oil pan capacity, L (qt.)	7.3 (7.7)
Oil pan capacity with filter, L (qt.)	8.2 (8.7)
Oil filter: quantity, type	1, Cartridge
Oil cooler	Water-Cooled

Application Data

Cooling

Radiator System	
Ambient temperature, °C (°F)	50 (122)
Engine jacket water capacity, L (gal.)	2.6 (0.7)
Radiator system capacity, including engine, L (gal.)	11.4 (3.0)
Engine jacket water flow, Lpm (gpm)	91 (24)
Heat rejected to cooling water at rated kW, dry exhaust, kW (Btu/min.)	24.8 (1412)
Water pump type	Centrifugal
Fan diameter, including blades, mm (in.)	597 (23.5)
Fan, kWm (HP)	2.9 (3.9)
Max. restriction of cooling air, intake and discharge side of radiator, kPa (in. H_2O)	0.125 (0.5)

Remote Radiator System†	
Exhaust manifold type	Dry
Connection sizes:	
Water inlet, ID hose, mm (in.)	51 (2.00)
Water outlet, ID hose, mm (in.)	48 (1.88)
Static head allowable above engine, kPa (ft. H_2O)	63 (21)

† Contact your local distributor for cooling system options and specifications based on your specific application.

Operation Requirements

Air Requirements	
Radiator-cooled cooling air, m^3/min. (scfm)‡	96 (3400)
Cooling air required for generator set when equipped with city water cooling or remote radiator, based on 14°C (25°F) rise and ambient temp. of 29°C (85°F), m^3/min. (cfm)	48 (1700)
Combustion air, m^3/min. (cfm)	3.0 (106)
Heat rejected to ambient air:	
Engine, kW (Btu/min.)	8.6 (490)
Alternator, kW (Btu/min.)	4.4 (250)

‡ Air density = 1.20 kg/m^3 (0.075 lbm/ft^3)

Fuel Consumption		
Diesel, Lph (gph) at % load	**Standby Rating**	
100%	10.6	(2.8)
75%	8.0	(2.1)
50%	5.8	(1.5)
25%	3.9	(1.0)
Diesel, Lph (gph) at % load	**Prime Rating**	
100%	9.4	(2.5)
75%	7.2	(1.9)
50%	5.2	(1.4)
25%	3.4	(0.9)

Controllers



Decision-Maker® 550 Controller
Provides advanced control, system monitoring, and system diagnostics with remote monitoring capabilities.

- Digital display and keypad provide easy local data access
- Measurements are selectable in metric or English units
- Remote communication thru a personal computer via network or modem configuration
- Controller supports Modbus® protocol
- Integrated voltage regulator with ±0.25% regulation
- Built-in alternator thermal overload protection
- NFPA 110 Level 1 capability

Refer to G6-46 for additional controller features and accessories.



Decision-Maker® 3000 Controller
Provides advanced control, system monitoring, and system diagnostics for optimum performance and compatibility.

- Digital display and menu control provide easy local data access
- Measurements are selectable in metric or English units
- Scrolling display shows critical data at a glance
- Integrated hybrid voltage regulator with ±0.5% regulation
- Built-in alternator thermal overload protection
- NFPA 110 Level 1 capability

Refer to G6-100 for additional controller features and accessories.

KOHLER CO., Kohler, Wisconsin 53044 USA
Phone 920-565-3381, Fax 920-459-1646
For the nearest sales and service outlet in the
US and Canada, phone 1-800-544-2444
KohlerPower.com

Kohler Power Systems
Asia Pacific Headquarters
7 Jurong Pier Road
Singapore 619159
Phone (65) 6264-6422, Fax (65) 6264-6455

Additional Standard Features

- Alternator Protection
- Battery Rack and Cables
- Oil Drain and Coolant Drain w/Hose Barb
- Oil Drain Extension (with narrow skid and enclosure models only)
- Operation and Installation Literature
- Radiator Drain Extension (with enclosure only)

Available Options

Approvals and Listings

- ❑ CSA Approval
- ❑ IBC Seismic Certification
- ❑ UL2200 Listing

Enclosed Unit

- ❑ Sound Enclosure (with enclosed critical silencer)
- ❑ Weather Enclosure (with enclosed critical silencer)

Open Unit

- ❑ Exhaust Silencer, Critical (kit: PA-352663)
- ❑ Exhaust Silencer, Hospital (kit: GM32386-KP1)
- ❑ Flexible Exhaust Connector, Stainless Steel

Fuel System

- ❑ Auxiliary Fuel Pump
- ❑ Flexible Fuel Lines
- ❑ Fuel Pressure Gauge
- ❑ Subbase Fuel Tanks

Controller

- ❑ Common Failure Relay
- ❑ Communication Products and PC Software (550 controller only)
- ❑ Customer Connection (550 controller only)
- ❑ Dry Contact (isolated alarm) (550 controller only)
- ❑ Input/Output Module (3000 controller only)
- ❑ Prime Power Switch
- ❑ Remote Annunciator Panel
- ❑ Remote Audiovisual Alarm Panel (550 controller only)
- ❑ Remote Emergency Stop
- ❑ Remote Mounting Cable (550 controller only)
- ❑ Run Relay

Cooling System

- ❑ Block Heater; Recommended for Ambient Temperatures Below 0°C (32°F)
- ❑ Radiator Duct Flange
- ❑ Remote Radiator Setup

Electrical System

- ❑ Alternator Strip Heater
- ❑ Battery
- ❑ Battery Charger, Equalize/Float Type
- ❑ Battery Heater
- ❑ Line Circuit Breaker (NEMA type 1 enclosure)
- ❑ Line Circuit Breaker with Shunt Trip (NEMA type 1 enclosure)

Paralleling System

- ❑ Reactive Droop Compensator
- ❑ Voltage Adjust Control
- ❑ Voltage Regulator Relocation (550 controller only)

Miscellaneous

- ❑ Air Cleaner, Heavy Duty
- ❑ Air Cleaner Restriction Indicator
- ❑ Closed Crankcase Vent
- ❑ Engine Fluids (oil and coolant) Added
- ❑ Rated Power Factor Testing
- ❑ Rodent Guards
- ❑ Skid End Caps

Literature

- ❑ General Maintenance
- ❑ NFPA 110
- ❑ Overhaul
- ❑ Production

Warranty

- ❑ 2-Year Basic
- ❑ 2-Year Prime
- ❑ 5-Year Basic
- ❑ 5-Year Comprehensive
- ❑ 10-Year Major Components

Other Options

- ❑ _____
- ❑ _____
- ❑ _____

Dimensions and Weights

Overall Size, L x W x H, mm (in.):
Wide Skid: 2300 x 1040 x 1133 (90.55 x 40.94 x 44.61)
Narrow Skid: 1998 x 780 x 1067 (78.66 x 30.71 x 42.01)
Weight (radiator model), wet, kg (lb.): 735 (1620)



NOTE: This drawing is provided for reference only and should not be used for planning installation. Contact your local distributor for more detailed information.

DISTRIBUTED BY: